



# Series PFC850-1500 Boilers Vent Piping Material Update - Supplement to Installation Manual

The information in this supplement supersedes and updates information shown in the Boiler Installation, Operation and Maintenance Manual (PF8302 R3) regarding the section on Venting & Air Inlet Piping.

**Table 3.1: Approved Materials for Exhaust Vent Pipe**

Description	Material	Conforming to Standard
Exhaust Vent Piping & Fittings	PVC (Sch 40 or 80)*	ANSI/ASTM D1785
	CPVC (Sch 40 or 80)	ANSI/ASTM D1785
	PVC-DWV*	ANSI/ASTM D2665
	DuraVent FasNSeal® AL29-4c Stainless	UL-1738
	DuraVent PolyPro® Polypropylene	ULC-S636
	Z-Flex Z-DENS®	ULC-S636
	Z-Flex Z-Vent AL29-4c Stainless	UL-1738 & ULC-S636
	CentroTherm InnoFlue® Polypropylene	ULC-S636

\* PVC pipe/fittings are not to be used for venting within confined spaces.