

In Canada, plastic pipe and fittings used to vent flue gases including PVC, CPVC & PP must be certified to ULC-S636 Standard for Type BH Gas Venting Systems and shall be installed in accordance with the terms of its listing.

The following are excerpts and link to CAN/CSA-B149.1S1-07 Natural gas and propane installation code supplement:

[8.9.6](#)

[Vents constructed using plastic piping shall be certified to ULC S636.](#)

[8.10.4](#)

[A special venting system or a BH venting system shall be installed in accordance with the terms of its listing and the appliance and vent manufacturer's certified installation instructions.](#)

ULC-S636 Standard for Type BH Gas Venting Systems Class II venting systems are suitable for gas-fired appliances producing flue gas temperatures of:

- Class II A: Up to and including 65C (149F) - Listed PVC Vent
- Class II B: Up to and including 90C (194F) - Listed CPVC Vent
- Class II C: Up to and including 110C (230F) - Listed PP Vent

U.S.A.

20 Commerce Park North, Bedford, NH 03110-6911
Tel: 603.669.5136 Fax: 888.889.3539 Toll Free: 800.654.5600

CANADA

452 Atwell Drive, Etobicoke, ON M9W 5C3
Tel: 416.679.0045 Fax: 416.679.0051

rev 6.2018