

Z-DENS[®] Concentric

ULC-S636 Listed Category II, IV Polypropylene Gas Vent

www.z-flex.com

1-800-654-5600

PART 1 GENERAL

1.1 SCOPE

- A. All work in this Section shall comply with the Mechanical General Specifications for this job, if any.
- B. This Section includes specifications for furnishing and installing of a ULC-S636 Listed Concentric Vent/Air for Category II, IV Gas Fired Appliances.

1.2 SUBMITTALS

Submit the following for the Vent/Air System in accordance with this Section:

- A. Layout Drawings
- B. Sizing Calculations
- C. Product Catalog
- D. Installation Instructions
- E. Product Warranty

1.3 CODES AND APPLICABLE STANDARDS

Gas Vent/Air System furnished under this Section shall be listed to ULC-S636 Vent Standard and installed in accordance with all applicable local, state and national and provincial codes, ordinances, regulations and laws such as The National Fuel Gas Code, ANSI Z223.1/NFPA-54 (USA) or Natural Gas and Propane Installation Code, B149.1 (Canada) or such codes as BOCA National Mechanical Code, the Standard Mechanical Code, the Uniform Mechanical Code where applicable.

1.4 WARRANTIES

The manufacturer shall warrant the Concentric System against defects in material and workmanship for a period of 10 years from the date of installation. Any concentric repaired or replaced under the warranty shall be warranted for the remainder of the original warranty period.

PART 2 PRODUCTS

2.1 ULC-S636 Listed Concentric Vent/Air for Category II, IV Gas Fired Appliances

- A. The factory built concentric vent/air shall be engineered for use with category II, IV gas fired appliances or as specified by the gas fired appliance manufacturer.
- B. Inner vent shall be constructed of fire retardant polypropylene with an outside diameter and wall thickness of: Outside Diameter Min.Wall Thickness Max. Wall Thickness

| Outside Diameter | | | Min.Wall Thickness | | Max. Wall Thick | |
|------------------|-----|------|--------------------|------|-----------------|------|
| | mm | Inch | mm | Inch | mm | Inch |
| | 60 | 2.36 | 1.8 | 0.07 | 2.2 | 0.09 |
| | 80 | 3.15 | 2.0 | 0.08 | 2.4 | 0.09 |
| | 110 | 4.33 | 2.6 | 0.10 | 3.0 | 0.12 |
| | | | | | | |

- C. Inner vent shall include a factory installed Double Fail Safe gasket in the female end of vent yielding an air and water tight joint when the overlapping male/female ends are assembled per the vent manufacturer's instructions.
- D. The outer air wall shall be constructed of powdered coated galvanized steel or aluminum.
- E. The outer air wall shall incorporate an overlapping joint closure system which is secured together with provided screws.
- F. Concentric vent/air shall be compatible to single wall vent with an adaptor all from the same vent manufacturer.
- G. Maximum Intertek rated vent gas temperature shall not exceed 230°F.
- H. Vent shall be Intertek rated for a maximum pressure of 20" w.c.
- I. The vent/air system shall be continuous from the appliance outlet to the termination outside the building. All systems components such as supports, roof or wall penetrations, terminations, connectors and drain fittings shall be Intertek listed and supplied by the same vent manufacturer.
- J. Concentric components in direct contact with products of combustion must include a Intertek label.

2.2 MANUFACTURER

Vent/Air shall be Z-DENS[®] Concentric manufactured by Z-Flex U.S. or Flexmaster Canada.



Z-DENS[®] Concentric

ULC-S636 Listed Category II, IV Polypropylene Gas Vent

www.z-flex.com

1-800-654-5600

PART 3 EXECUTION

3.1 VENT/AIR SYSTEM LAYOUT

- A. The vent/air system and breachings shall be cleaned and inspected before connecting to appliance.
- B. The vent/air system shall maintain air space clearances to combustibles as specified by the manufacturer.
- C. Vent/Air layout shall be designed and installed in compliance with manufacturer's installation instructions including vent category, vent diameter, maximum equivalent length and/or allowable vent pressures, number of elbows, condensate drains, terminations, slope, clearances, support, etc.
- D. Vent/Air system installation shall conform to the manufacturer's installation instructions, its Intertek listing and state/local codes.

3.2 MECHANICAL EQUIPMENT

A. Support any dampers or fans installed in the vent system to prevent any twisting or movement of vent system from fan torque or vibration.

The information provided within is for informational purposes only. We have made every effort to ensure the accuracy of the provided information and assume no responsibility for any loss or damage due to errors or omissions or to the use or misuse of any information supplied. It is impossible to test all products under all conditions to which they might be subjected in the field. It is therefore the buyer and/ or end users' responsibility to test all products under the conditions that duplicate the service conditions prior to installation. All improvements, all specifications are subject to change without prior notice. It is the buyer and/or end users' responsibility to review our complete Terms and Conditions of Sale located on our web sites at: www.novaflex.com | www.z-flex.com | www.flexmaster.com