



PeerlessBoilers.com

Mr. Kurt Bauer
Z-Flex U.S. Inc.
1024 Industrial Drive
West Berlin, NJ 08091

October 6, 2015

Reference: Approval of Z-Flex's Z-DENS Polypropylene Vent for Use on All Peerless® PureFire® Models

Dear Mr. Bauer,

This letter is to confirm Z-Flex's Z-DENS polypropylene single wall rigid, flexible and concentric vent systems are now approved for use on all Peerless® PureFire® models.

There will be no change in already approved vent lengths and both vent diameters and terminations will be comparable to already approved options. The Z-DENS product will be listed in our IOM instructions on Table 3.1: Approved Materials for Exhaust Vent Pipe when it is convenient.

Please contact me if you have any questions or require any additional information.

Kind Regards,

David A. Scarce, P.E.